

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016427.07
DATE: 12/10/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "8700" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-2184mm(86") H-1676mm(66") Sash: W-1080mm(42.50") H-1584mm(62.38") DLO: W-1003mm(39.50") H-1505mm(59.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG15 2184 x 1676 (86 x 66)-HS Design Pressure: ± 720 Pa (± 15 psf) Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D8503.01-109-47
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023