

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016437.05
DATE: 12/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "3000/3900 3003/3903/3020/3920" Vinyl Triple Double Hung Window Configuration: X/XX/XX/X Glazing: Insulating Glass (Annealed) Frame: W-2724mm(107.25") H-1448mm(57") Sash: W-845mm(33.25") H-719mm(28.31") DLO: W-746mm(29.38") H-638mm(25.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 2724 x 1448* (107 x 57*)-H Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D4551.01-109-47/D4553.01-109-47
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023