

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016437.07
DATE: 12/19/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series “3000/3900 3001/3901 Vinyl Double Hung Window (Fin) Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1949mm(76.75") Sash: W-1156mm(45.50") H-973mm(38.31") DLO: W-1064mm(41.88") H-892mm(35.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG25 1219 x 1949 (48 x 77)-H Design Pressure: ±1200 Pa (±25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested : Intertek, PLC
Report No: E8270.01-109-47
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023