

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016437.09
DATE: 12/19/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series “3000/3900 3002/3902 Vinyl Twin Double Hung Window Configuration: X/XX/X Glazing: Insulating Glass (Annealed) Frame: W-2438mm(96") H-1600mm(63") Sash: W-1153mm(45.38") H-799mm(31.44") DLO: W-1057mm(41.63") H-714mm(28.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG30 2438 x 1600 (96 x 63)-H Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested : Intertek, PLC
Report No: D4553.01-109-47
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023