

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016437.12
DATE: 12/19/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series “3000/3900 3002/3902 Vinyl Twin Double Hung Window (Fin) Configuration: X/XX/X Glazing: Insulating Glass (Annealed) Frame: W-1930mm(76") H-1949mm(76.75") Sash: W-899mm(35.38") H-972mm(38.25") DLO: W-806mm(31.75") H-743mm(29.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG40 1930 x 1949* (76 x 77*)-H Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 220 Pa (6.06 psf)

Product Tested : Architectural Testing, Inc.
Report No: D7162.01-109-47/D4553.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023