NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016438.01**
DATE:	**12/16/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Silverline**
CODE:	**3108-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "1200 1200 DH"** **Vinyl Double Hung Window** Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1829mm(72") Sash: W-1130mm(44.50") H-905mm(35.63") DLO: W-1060mm(41.75") H-835mm(32.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class R-PG20 1219 x 1829 (48 x 72)-H** **Design Pressure: ±960 Pa (±20 psf)** **Water Penetration Resistance Test Pressure: 150 Pa (3.13 psf)**

Product Tested By: Architectural Testing
Report No: D2938.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com