

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016439.01  
DATE: 12/17/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Silverline  
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                   | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                           |
|--------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Silverline Building Products</b><br><b>5020 Weston Parkway</b><br><b>Cary, NC 27513</b> | <b>Series “3600 Impact”</b><br><b>Vinyl Double Hung Window</b><br><br>Configuration: X/X<br>Glazing: IG-Ext. 1/8" Annealed Glass/Int. 1/8" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/1/8" Annealed Glass<br><br>Frame: W-1172mm(46.13") H-1832mm(72.13")<br><br>Sash: W-1102mm(43.38") H-902mm(35.50")<br><br>DLO: W-1010mm(39.75") H-822mm(32.38") |

| SPECIFICATION                                                                                                                                                                                 | PRODUCT RATING                                                                                                                                                                                                                                 |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>ASTM E1886-19/ASTM E1996-20</b><br><b>TAS 201/202/203-94</b> | <b>Class R-PG50 1168 x 1829 (46 x 72)-H</b><br><b>Design Pressure: ±2400 Pa (±50 psf)</b><br><b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b><br><b>Missile Level D - Wind Zone 3</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: Molimo, LLC  
Report No: 12340.01-106-13/12340.02-106-11  
Expiration Date: December 31, 2028

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)