

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016449.02
DATE: 12/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "5500/5700 5502/5702" Vinyl Two Panel Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1819mm(71.63") H-2026mm(79.75") Panel: W-902mm(35.50") H-1975mm(77.75") DLO: W-797mm(31.38") H-1854mm(73")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 1819 x 2026 (72 x 80)-SD Design Pressure: ± 1680 Pa (± 35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Intertek, PLC.
Report No: E6284.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023