

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016449.03  
DATE: 12/26/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Silverline  
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                   | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                     |
|--------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Silverline Building Products</b><br><b>5020 Weston Parkway</b><br><b>Cary, NC 27513</b> | <b>Series "5500/5700 5502/5702"</b><br><b>Vinyl Two Panel Sliding Door</b><br><br>Configuration: XO<br>Glazing: Insulating Glass (Tempered)<br>Frame: W-2429mm(95.63") H-2083mm(82")<br>Panel: W-1207mm(47.50") H-2026mm(79.75")<br>DLO: W-1099mm(43.25") H-1905mm(75") |

| SPECIFICATION                          | PRODUCT RATING                                                                                                                                                                              |
|----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> | <b>Class R-PG25 2429 x 2083 (96 x 82)-SD</b><br><b>Design Pressure: <math>\pm 1200</math> Pa (<math>\pm 25</math> psf)</b><br>Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) |

Product Tested By: Intertek, PLC.  
Report No: E6284.01-109-47  
Expiration Date: **December 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023