

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016450.03
DATE: 12/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "5800/5802" Vinyl Two Panel Sliding Door (Fin & Finless) Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1819mm(71.63") H-2032mm(80") Panel: W-927mm(36.50") H-1956mm(77") DLO: W-806mm(31.75") H-1832mm(72.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 1819 x 2032 (72 x 80)-SD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Intertek, PLC.
Report No: F5838.01-109-47
Expiration Date: **December 31, 2028**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023