

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016450.08
DATE: 12/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "5800/5802" Vinyl Sliding Glass Door (Nail Fin & Flange Installations) Configuration: XO Glazing: IG-Ext. 3/32" Tempered Glass/Int. 1/8" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1829mm(72") H-2045mm(80.50") Panel: W-953mm(37.50") H-2007mm(79") DLO: W-832mm(32.75") H-1886mm(74.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01410070
Expiration Date: December 31, 2028

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023