NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016450.09**
DATE:	**02/05/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Silverline**
CODE:	**3108-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products **5020 Weston Parkway** **Cary, NC 27513**	**Series "5800/5810"** **Vinyl Sliding Glass Door** **(Fin Models)** Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1819mm(71.63") H-2083mm(82") Panel: W-932mm(36.69") H-2004mm(78.88") DLO: W-810mm(31.88") H-1884mm(74.18")

SPECIFICATION	PRODUCT RATING
TAS 202-94	**Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01410090
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com