

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016450.10
DATE: 02/05/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "5800/5810" Vinyl Sliding Glass Door (Flange Models) Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1819mm(71.63") H-2083mm(82") Panel: W-932mm(36.69") H-2004mm(78.88") DLO: W-810mm(31.88") H-1884mm(74.18")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01410090
Expiration Date: January 31, 2029

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023