

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011872.01-R1
DATE: 02/25/2014
CERTIFICATION PROGRAM: Structural
COMPANY: NewSouth
CODE: 2013-1
REVISION DATE: 09/16/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610 | Series "4600" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72.00") H-1930mm(76.00") DLO: W-1749mm(67.87") H-1851mm(72.87") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 | Class CW-PG60 1829 x 1930 (72 x 76)-FW FW-C60 1829 x 1930 (72 x 76) Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf) |

Product Tested By: Architectural Testing Incorporated
Report No: C0574.02-501-47
Expiration Date: November 30, 2016

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122