

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012789.06  
**DATE:** 09/16/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** NewSouth  
**CODE:** 2013-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Doers Window Manufacturing, LLC</b> <b>4901 Oak Fair Boulevard</b> <b>Tampa, FL 33610</b>	<b>Series "4650" Impact Rated</b> <b>Vinyl Fixed Window</b> <b>New Construction</b>  Configuration: O Glazing: IG-1/8" Annealed Glass/ Laminate-1/8" Annealed Glass/0.090" DuPont SGP Interlayer/1/8" Annealed Glass  Frame: W-1829mm(72") H-1930mm(76") DLO: W-1742mm(68.6") H-1844mm(72.6")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: 2155 Pa (45 psf)</b> <b>Negative Design Pressure: 2633 Pa (55 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Element Materials Technology, Inc.  
Report No: ESP 011398P-1A\_D  
Expiration Date: September 30, 2016

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**