## NOTICE OF PRODUCT CERTIFICATION •



**CERTIFICATION NO:** 

NI011858.12

DATE:

02/20/2014

**CERTIFICATION PROGRAM:** 

Structural

**COMPANY:** 

NewSouth

CODE:

2013-1

To verify that the "Notice of Product Certification" is valid, please visit <a href="www.NAMICertification.com">www.NAMICertification.com</a> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC	Series "9000" Model "9600"
4901 Oak Fair Boulevard	New Construction Frame
Tampa, FL 33610	Vinyl Fixed Window
	Configuration: O Glazing: Insulating Glass (Annealed)
	Frame: W-1219mm(48.00") H-1219mm(48.00")
	DLO: W-1111mm(43.75") H-1111mm(43.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG100 1219 x 1219 (48 x 48)-FW Design Pressure: 4800 Pa (100 psf) Negative Design Pressure: 4800 Pa (100 psf) Water Penetration Resistance Test Pressure: 720 Pa(15.04 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By:

Architectural Testing Incorporated

Report No:

C6764.07-501-44

Expiration Date:

January 31, 2018

Administrator's Signature:

Shi

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122