

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011760.02  
DATE: 09/15/2015  
CERTIFICATION PROGRAM: Structural  
COMPANY: NewSouth  
CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Doers Window Manufacturing, LLC</b> <b>4901 Oak Fair Boulevard</b> <b>Tampa, FL 33610</b>	<b>Series "TrustSeries"</b> <b>Vinyl Fixed Window</b> <b>Replacement</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1524mm(60") H-1905mm(75") DLO: W-1443mm(56.93") H-1826mm(71.87")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class CW-PG40 1524 x 1905 (60 x 75)-FW</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa(7.52 psf)</b>

Product Tested By: Architectural Testing Incorporated  
Report No: A7699.03-501-44  
Expiration Date: January 31, 2016

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122