

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012638
DATE: 05/06/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Doers
CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	Series "Sashlite" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-1422mm(56") DLO: W-1251mm(49.25") H-1251mm(49.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/LS.2/A440-08	Class R-PG55 1422 x 1422 (56 x 56)-FW Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02031258
Expiration Date: February 28, 2019

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122