

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI014260.01-R3
DATE:	11/13/2018
CERTIFICATION PROGRAM:	Structural
COMPANY:	Ply Gem
CODE:	1408-1
REVISION DATE:	02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Pro Classic/1500/5700" Vinyl Fixed Panel Side Lite Configuration: O Glazing: Insulated Glass (Tempered) Frame: W-970mm(38.19) H-2426mm(95.5") Panel: W-889mm(35") H-2362mm(93") DLO: W-778mm(30.63") H-2245mm(88.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG60 965 x 2083* (38 x 96*)-SLT Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.96 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-21569-1/NCTL-110-21568-1/W-2010
Expiration Date: **August 30, 2030**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023