

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014369.01-R2
DATE: 03/26/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 05/14/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Pro Classic/1500/5700" Vinyl Fixed Transom Window Configuration: O Glazing: Insulated Glass (Annealed) Frame: W-2426mm(95.5") H-972mm(38.25") Sash: W-2362mm(93") H-902mm(35.5") DLO: W-2238mm(88.13") H-781mm(30.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-17	Class LC-PG55 2426 x 972 (96 x 38)-TR Design Pressure: ±2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-21906-1
Expiration Date: October 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023