

# NOTICE OF PRODUCT CERTIFICATION



|                        |                |
|------------------------|----------------|
| CERTIFICATION NO:      | NI014259.01-R3 |
| DATE:                  | 11/13/2018     |
| CERTIFICATION PROGRAM: | Structural     |
| COMPANY:               | Ply Gem        |
| CODE:                  | 1408-1         |
| REVISION DATE:         | 02/18/2026     |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                         |
|---------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>Series "Pro Classic/1500/5700"</b><br><br><b>Vinyl Sliding Patio Door</b><br><br>Configuration: OX<br>Glazing: Insulated Glass (Tempered)<br><br>Frame: W-1816mm(71.5") H-2070mm(81.5")<br>Panel: W-903mm(35.56") H-2005mm(78.94")<br>DLO: W-781mm(30.75") H-1880mm(74") |

| SPECIFICATION                                                                                         | PRODUCT RATING                                                                                                                                                                                                           |
|-------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-17<br>AAMA/WDMA/CSA 101/I.S.2/A440-11<br>AAMA/WDMA/CSA 101/I.S.2/A440-08 | <b>Class LC-PG50 1828 x 2083* (72 x 82*)-SD</b><br><b>Design Pressure: ±2640 Pa (55 psf)</b><br>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)<br><b>Canadian Air Infiltration/Exfiltration Level: A2</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-21567-1/NCTL-110-21566-1/W-1953/W-2010  
Expiration Date: August 30, 2030

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023