

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009476-R9
DATE: 05/21/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4701 FIR" Aluminum Impact Rated Fixed Window Configuration: O Glazing: IG-5/32" Annealed Glass/1/4" Aluminum Spacer/Laminate-1/8" Annealed Glass/0.090" DuPont SGP Interlayer/ 1/8" Annealed Glass Frame: W-1346mm(53") H-1880mm(74") DLO: W-1251mm(49.25") H-1784mm(70.25")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/11/16 ASTM E1886-05/13a/19 ASTM E1996-05b/09/14a/20 AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG40 1346 x 1880 (53 x 74)-FW F-R40 1346 x 1880 (53 x 74) Design Pressure: ±1915 Pa (±40 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.0 psf) Impact Rating: Design Pressure: +50/-57 psf Wind Zone 3-Missile Level D

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI-08-087/W-1958/W-2047
Expiration Date: May 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023