

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010961.01-R3
DATE: 02/06/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 12/13/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	"Aluminum Clad Wood Awning" Aluminum Clad Wood Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1200mm(47.25") H-800mm(31.5") Vent: W-1143mm(45.38") H-737mm(29.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	CW-PG95 1200 x 800 (47 x 31)-AP AP-C95 1200 x 800 (47 x 31) Design Pressure: 4560 Pa (95 psf) Negative Design Pressure: 4560 Pa (95 psf) Water Penetration Resistance Test Pressure: 730 Pa (15.0 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.
Report No: 86559.01.01-201-44/86558.01-201-44/W-1921
Expiration Date: **December 31, 2026**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com