

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013177.02-R2
DATE: 05/09/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 10/04/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	Series "Traditional" Aluminum Clad Wood Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1700mm(66.94") H-1350mm(53.19") Vent: W-1653mm(65.06") H-1303mm(51.25") DLO: W-1547mm(60.88") H-1192mm(46.94")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG50 1700 x 1350 (67 x 53)-AP Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.
Report No: F5742.01-750-44/W-1921
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023