NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI010959.01-R3**
DATE:	**02/06/2012**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Loewen**
CODE:	**1862-1**
REVISION DATE:	**12/13/2021**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen **77 Highway 52 West** **Steinbach, Manitoba R5G 1B2**	**"Aluminum Clad Wood Casement"** **Aluminum Clad Wood Casement Window** Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-800mm(31.5") H-1500mm(59.06") Vent: W-753mm(29.63") H-1449mm(57.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**LC-PG80 800 x 1500 (32 x 59)-C** **C-LC80 800 x 1500 (31 x 59)** **Design Pressure: 3840 Pa (80 psf)** **Negative Design Pressure: 3840 Pa (80 psf)** **Water Penetration Resistance Test Pressure: 730 Pa (15.0 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Architectural Testing, Inc.
Report No: 86557.01-201-44/86554.01.01-201-44/W-1921
Expiration Date: **December 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com