

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013235-R2  
**DATE:** 06/06/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Loewen  
**CODE:** 1862-1  
**REVISION DATE:** 10/04/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                         | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                               |
|----------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Loewen</b><br><b>77 Highway 52 West</b><br><b>Steinbach, Manitoba R5G 1B2</b> | <b>Series "Fixed Casement"</b><br><b>Aluminum Clad Wood</b><br><b>Fixed Casement Window</b><br><br>Configuration: O<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-2667mm(105") H-2438mm(96")<br><br>Vent: W-2620mm(103.13") H-2390mm(94.13")<br><br>DLO: W-2514mm(99") H-2280mm(89.75") |

| SPECIFICATION                                                                                            | PRODUCT RATING                                                                                                                                                                                                                    |
|----------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>CSA A440S1-09</b> | <b>Class CW-PG55 2667 x 2438 (105 x 96)-FW</b><br><b>Design Pressure: 2640 Pa (55 psf)</b><br><b>Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: Fixed</b> |

Product Tested By: Architectural Testing, Inc.  
Report No: F6725.01-750-44/W-1921  
Expiration Date: **June 30, 2027**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023