

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI014158.02-R4</u>
DATE:	<u>07/25/2018</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>Ply Gem</u>
CODE:	<u>1408-1</u>
REVISION DATE:	<u>08/06/2025</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira" Aluminum Clad Wood Awning Window Configuration: X Glazing: IG-1/8 Annealed Glass/1/8 Annealed Glass/0.090" PVB Interlayer/1/8 Annealed Glass Frame: W-1257mm(49.5") H-914mm(36") Vent: W-1218mm(47.94") H-872mm(34.31") DLO: W-1108mm(43.63") H-767mm(30.19")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG60 1245 x 914* (49 x 36*)-AP AP-LC60 1245 x 914* (49 x 36*) Design Pressure: ±2880 Pa (60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3360 Pa (70 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-21076-1/ NCTL-110-21051-1/NCTL-110-21052-1
Expiration Date: March 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOP C-03/30/2023