

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010089-R6  
DATE: 01/18/2010  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 03/03/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                    |
|---------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>“1500 Vinyl Collection (No Fin)”</b><br><b>Vinyl Out-Swing Casement Window</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-902mm(35.5") H-1816mm(71.5")<br>Vent: W-854mm(33.6") H-1768mm(69.6") |

| SPECIFICATION                                                                                                                                                        | PRODUCT RATING                                                                                                                                                                                                                                            |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> | <b>Class LC-PG45 902 x 1816 (36 x 72)-C</b><br><b>C-LC45 902 x 1816 (36 x 72)</b><br><b>Design Pressure: 2155 Pa (45 psf)</b><br><b>Negative Design Pressure: 2155 Pa (45 psf)</b><br><b>Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf)</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12326-1/W-1988  
Expiration Date: March 31, 2029

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023