

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014061.01-R2
DATE: 09/10/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/03/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira" Outswing Aluminum Clad Wood Casement Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-914mm(36") H-1829mm(72") Vent: W-870mm(34.25") H-1784mm(70.25") DLO: W-765mm(30.13") H-1680mm(66.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11/16 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Wind Zone 3 - Missile Level D Class LC-PG60 914 x 1829* (36 x 72*)-C Design Pressure: +2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-21376-1/NCTL-110-20986-1/W-1988
Expiration Date: May 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023