

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010766.01-R6
DATE: 11/02/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira Impact" Aluminum Clad Wood Impact Rated Out-Swing Casement Sash Set Fixed Window Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass Frame: W-916mm(36.06") H-2286mm(90.00") DLO: W-767mm(30.19") H-2138mm(84.19")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA 506-06/08/11/16 ASTM E1886-02/05/13a/19 ASTM E1996-02/05/14/17/20	Class-LC45 916 x 2286 (36 x 90)-FW FW-LC45 916 x 2286 (36 x 90) Positive Design Pressure: 2394 Pa (50 psf) Negative Design Pressure: 2394 Pa (50 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-14374-1/NCTL-110-12765-4/W-2047
Expiration Date: March 31, 2029

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023