

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI014062-R2
DATE:	05/18/2018
CERTIFICATION PROGRAM:	Structural
COMPANY:	Ply Gem
CODE:	1408-1
REVISION DATE:	08/06/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira" Aluminum Clad Wood Casement Fixed Window (Sash Set) Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-2137mm(84.12") DLO: W-1735mm(66.31") H-1988mm(78.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-17	Class LC-PG40 1829 x 2137 (72 x 84)-FW FW-LC40 1829 x 2137 (72 x 84) Design Pressure: ±1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-20987-1/W-2010
Expiration Date: **January 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023