

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010763-R5
DATE: 10/31/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira Impact" Double Hung Sash and Frame Transom Aluminum Clad Wood Impact Rated Window Configuration: O Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass Frame: W-1254mm(49.38") H-746mm(29.38") DLO: W-1089mm(42.88") H-579mm (22.81")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11 ASTM E1886-02/05/E1996-02/05 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 1854 x 737 (73 x 29)-FW F-LC50 1854 x 737 (73 x 29) Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 4080 Pa (85 psf) Negative Design Pressure: 4080 Pa (85 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf) Wind Zone 3-Missile Level D F-LC50

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14367-1/CTLA-1842W/W-2010
Expiration Date: September 30, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023