

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009452.02-R2
DATE: 05/02/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1411-1
REVISION DATE: 11/19/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira Aluminum Clad Double Hung Window" w/Fin Frame Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-940mm(37") H-2057mm(81") Sash: W-883mm(34.75") H-1002mm (39.44")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG50 940 x 2057 (37 x 81)-H H-LC50 940 x 2057 (37 x 81) Design Pressure: 2394 Pa(50 psf) Negative Design Pressure: 3591 Pa (75 psf) Water Penetration Resistance Test Pressure: 359 Pa(7.5 psf)

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1794W/W-2010
Expiration Date: April 30, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023