NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI010474.03-R2**
DATE:	**06/20/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**03/01/2022**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "4712FIR/4712FLIR/4812FIR"** **Aluminum Single Hung** Configuration: O/X Glazing: IG-1/8" Annealed/Laminate-1/8" Annealed/0.090" Interlayer by Eastman/1/8" Annealed Glass Frame: W-1346mm(53") H-1829mm(72") Sash: W-1299mm(51.12") H-918mm(36.12")

SPECIFICATION	PRODUCT RATING
AAMA 506-08/11/16 **ASTM E1886-02/05/13a** **ASTM E1996-02/05/09/14a** **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class R-PG50 1346 x 1829 (53 x 72)-H** **H-R50 1346 x 1829 (53 x 72)** **Design Pressure: ±2400 Pa (±50 psf)** **Positive Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2873 Pa (60 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)** **Impact Rating:** **Design Pressure: +50/-57 psf** **Wind Zone 3-Missile Level D**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13420-1/NCTL-110-13262-1/NCTL-110-13262-2/W-1958
Expiration Date: **November 30, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Email: nami@namiinc.com