

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014350.02-R2
DATE: 02/28/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 09/27/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "American Craftsman 30/4700" Aluminum Single Hung Window (Non-Impact HVHZ Rated) Configuration: O/X Glazing: Insulated Glass (Annealed or Tempered) Frame: W-1324mm(52.13") H-1803mm(71") Sash: W-1280mm(50.38") H-910mm(35.81") DLO: W-1230mm(48.44") H-829mm(32.63")

SPECIFICATION	PRODUCT RATING
TAS-202-94	Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: J2927.02-550-18/I9308.01-550-18/W-1890
Expiration Date: **January 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com