

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010950-R6
DATE: 02/01/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 07/14/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	"Clad French Door" Aluminum Clad Wood Inswing Side Hinged Glass Door Configuration: XXO Glazing: Insulating Glass (Tempered) Frame: W-3245mm(127.25") H-2700mm(106.25") Panel: W-1056mm(41.56") H-2619mm(103.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	LC-PG25 3245 x 2700 (127 x 106)-SHD SHD-LC25 3245 x 2700 (127 x 106) Design Pressure: 1200 (25 psf) Positive Design Pressure: 1440 (30 psf) Negative Design Pressure: 1440 (30 psf) Water Penetration Resistance Test Pressure: 180 Pa(3.75 psf) Qualifies Configurations: O, X, OX, XO, XX, OXX, XXO

Product Tested By: Architectural Testing, Inc.
Report No: 96222.01-201-44/W-1742/W-1921
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023