# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI010951.01-R4** |
| **DATE:** | **02/01/2012** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **Loewen** |
| **CODE:** | **1862-1** |
| **REVISION DATE:** | **12/13/2021** |

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **Loewen**<br>**77 Highway 52 West**<br>**Steinbach, Manitoba R5G 1B2** | **"Wood French Door"**<br>**Wood Outswing**<br>**Side Hinged Glass Door**<br>Configuration: XX<br>Glazing: Insulating Glass (Tempered)<br>Frame: W-1829mm(72") H-2700mm(106.25")<br>Panel: W-902mm(35.5") H-2635mm(103.75") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-08**<br>**AAMA/WDMA/CSA 101/I.S.2/A440-05** | **LC-PG45 1829 x 2700 (72 x 106)-SHD**<br>**SHD-LC45 1829 x 2700 (72 x 106)**<br>**Design Pressure: 2160 (45 psf)**<br>**Negative Design Pressure: 2160 (45 psf)**<br>**Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf)**<br>**Qualifies Configurations: X, XX** |

Product Tested By: Architectural Testing, Inc.
Report No: 92077.01-201-44/W-1921
Expiration Date: **December 31, 2026**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**