

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011039-R3
DATE: 04/03/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ross Mfg
CODE: 1781-1
REVISION DATE: 11/10/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ross Manufacturing, LLC 155 Spire Lane New Braunfels, TX 78132	Series " Ross 2-IN-1 Ridge Vent" Polypropylene Roof Vents

SPECIFICATION	PRODUCT RATING
TAS 100(A)-95	Passed-110 mph Windspeed Passed-Water Resistance
ASTM E330-02	Design Pressure: +150/-150 psf

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: 6819/6831
Expiration Date: March 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122