

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011049.01-R2
DATE: 04/09/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 12/13/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	"Aluminum Clad Wood Fixed Door" Metal Clad French Patio Fixed Door Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1327mm(52.25") H-2699mm(106.25") DLO: W-1067mm(42") H-2235mm(88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	LC-PG100 1327 x 2699 (52 x 106)-FD FD-C100 1327 x 2700 (52 x 106) Design Pressure: 4800 (100 psf) Negative Design Pressure: 4800 (100 psf) Water Penetration Resistance Test Pressure: 720 Pa(15.0 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Architectural Testing, Inc.
Report No: B5118.01-750-44
Expiration Date: December 31, 2026

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com