

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010943-R4
DATE: 01/30/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 07/14/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	“Bi-Parting Clad Sliding Glass Door” Aluminum Clad Wood Bi-Parting Sliding Glass Door Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-4769mm(187.75") H-2400mm(94.49") Panel: W-1206mm(47.5") H-2362mm(93")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	LC-PG35 4769 x 2400 (187 x 94)-SD SD-LC35 4769 x 2400 (187 x 94) Design Pressure: 1680 (35 psf) Negative Design Pressure: 1680 (35 psf) Water Penetration Resistance Test Pressure: 290 Pa(6.0 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing, Inc.
Report No: 89338.01-201-44
Expiration Date: December 31, 2029

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOP C-03/30/2023