

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011051-R4
DATE: 04/09/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 07/14/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	"FP4 3627 Bi-Parting Sliding Glass Door" Aluminum Clad Wood Bi-Parting Sliding Glass Door Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3569mm(140.5") H-2700mm(106.31") Panel: W-908mm(35.75") H-2616mm(103")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG45 3569 x 2700 (140 x 106)-SD SD-C45 3569 x 2700 (140 x 106) Design Pressure: ±2160 (45 psf) Water Penetration Resistance Test Pressure: 330 Pa(6.75 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.
Report No: 76272.01-201-44/W-1966
Expiration Date: December 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023