

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012649
DATE: 05/11/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Doers
CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610</p>	<p style="text-align: center;">Series "6250" Impact Rated Vinyl Sliding Door</p> <p style="text-align: center;">Configuration: OX Glazing: IG-3/16" Tempered Glass/ Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by DuPont/1/8" Annealed Glass</p> <p>Frame: W-2438mm(96") H-2438mm(96") Panel: W-1261mm(49.63") H-2378mm(93.63") DLO: W-1007mm(39.63") H-2127mm(83.75")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">AAMA/WDMA/CSA 101/LS.2/A440-08 TAS 201/202/203-94 ASTM E1886-05/ASTM E1996-06</p>	<p style="text-align: center;">Class R-PG50 2438 x 2438 (96 x 96)-SD Design Pressure: 2394 Pa (50 psf) Negative Design Pressure: 2633 Pa (55 psf) Large Missile Impact Rated Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 359 Pa(7.5 psf)</p>

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: TEL 02031266/TEL 02031268/TEL 02031270
 Expiration Date: **March 31, 2019**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122