

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010424.01-R5
DATE: 12/10/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1411-1
REVISION DATE: 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Premium Series Mira Casement Elongated Quarter Circle" Out-Swing Aluminum Clad Wood Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-718mm(28.25") H-1978mm(77.87") DLO: W-575mm(22.62") H-1835mm(72.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG50 718 x 1978 (28 x 78)-C C-R50 718 x 1981 (28 x 78) Design Pressure: 2392 Pa (50 psf) Negative Design Pressure: 2871 Pa (60 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12765-2/W-2010
Expiration Date: August 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023