

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010764-R6
DATE: 10/31/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 03/03/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira Impact" Fixed Panel Aluminum Clad Wood Impact Rated Window Configuration: O Glazing: IG-Int-1/8" Tempered Glass/ Ext-Laminate-1/8" Annealed Glass/0.090" Eastman Chemical Interlayer/1/8" Annealed Glass Frame: W-1254mm(49.38") H-1946mm(76.62") Sash: W-1089mm(42.88") H-1749mm (68.88")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08/11 ASTM E1886-02/05/E1996-02/05 AAMA/WDMA/CSA 101/I.S.2/A440-05	Design Pressure: +50/-50 psf Wind Zone 3-Missile Level D Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) F-LC50

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14366-1/CTLA-1795W
Expiration Date: December 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com