

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010747.02-R5  
DATE: 09/30/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                              |
|---------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Premium Series Mira"</b><br><b>Aluminum Clad Wood</b><br><b>Sliding Glass Door</b><br><br>Configuration: OXXO<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-4791mm(188.63") H-2511mm(98.87")<br>Panel: W-1219mm(48") H-2438mm(96") |

| SPECIFICATION                                                                                                                            | PRODUCT RATING                                                                                                                                                                                                |
|------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-17<br>AAMA/WDMA/CSA 101/I.S.2/A440-11<br>AAMA/WDMA/CSA 101/I.S.2/A440-08<br>AAMA/WDMA/CSA 101/I.S.2/A440-05 | <b>Class LC-PG40 4791 x 2511 (189 x 99)-SD</b><br><b>SD-LC40 4791 x 2511 (189 x 99)</b><br><b>Design Pressure: ±1920 Pa (±40 psf)</b><br><b>Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)</b> |

Product Tested By: Architectural Testing, Inc.  
Report No: B2832.01-109-44/W-2010  
Expiration Date: September 30, 2030

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023