

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012586.01-R5
DATE: 03/22/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Mira" Aluminum Clad Wood Sliding Door Configuration: OXO Glazing: IG-Int-1/8" Tempered Glass/ Ext-Laminate-1/8" Annealed Glass/0.090" Eastman Solutia Saflex Interlayer/1/8" Annealed Glass Frame: W-2759mm(108.63") H-2427mm(95.56") Panel: W-913mm(35.94") H-2353mm(92.63")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 2759 x 2427 (109 x 96)-SD SD-LC50 2759 x 2427 (109 x 96) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf) Wind Zone 3-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17782-1/NCTL-110-14201-1/W-2010
Expiration Date: November 30, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023