

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010617-R4  
**DATE:** 05/12/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 08/06/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                             |
|---------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Ply Gem Window Group</b><br><b>433 North Main Street</b><br><b>Rocky Mount, VA 24151</b> | <b>"Mira Out-Swing French Hinged Door"</b><br><br><b>Aluminum Clad Wood</b><br><br><b>Side Hinged Door</b><br><br>Configuration: XX<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1892mm(74.5") H-2486mm(97.87")<br>Panel: W-914mm(36") H-2438mm(96") |

| SPECIFICATION                                                                                                                                                        | PRODUCT RATING                                                                                                                                                                                                                                                  |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> | <b>Class LC-PG50 1892 x 2486 (75 x 98)-SHD</b><br><b>SHD-LC50 1892 x 2486 (75 x 98)</b><br><b>Design Pressure: 2394 Pa (50 psf)</b><br><b>Negative Design Pressure: 2394 Pa (50 psf)</b><br><b>Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-13904-1/W-2010  
Expiration Date: March 31, 2030

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi D".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023