

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010617.04-R4
DATE: 07/25/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/20/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Mira Out-Swing French Hinged" Aluminum Clad Wood Door" Side Hinged Door Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3799mm(149.56") H-2494mm(98.06") Panel: W-916mm(36.06") H-2080mm(81.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG45 3799 x 2494 (150 x 98)-SHD SHD-LC45 3799 x 2494 (150 x 98) Design Pressure: 2155 Pa (45 psf) Negative Design Pressure: 2155 Pa (45 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14074-1/W-2010
Expiration Date: May 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023