

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011066-R4
DATE: 04/20/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 02/14/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"Contractor Series 2000/HarborLight/ Home Craftsman 8150/Mastic 3000" Vinyl Tilt Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-940mm(37") H-789mm(31.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class R-PG55 1016 x 1600 (40 x 63)-H H-R55 1016 x 1600 (40 x 63) Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.35 psf) Canadian Air Infiltration/Exfiltration Rate: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14795-1
Expiration Date: December 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com