

**AAMA  
CERTIFICATION PROGRAM**



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
**1 Cochrane Ave.**  
**Pennsboro, WV 26415**

**Attn: Tina Seese**

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-2724x1207 (107x48)-FW</b>	<b>AAMA 506</b>			
<b>COMPANY AND PLANT LOCATION</b>	Missile Level: <b>C</b> Rating: <b>+50/-50, 107x48</b> Wind Zone: <b>2</b> Rating above conforms to requirements of: <b>ASTM E1886 and E1996</b>	<b>CPD NO.</b>	<b>SERIES MODEL &amp; PRODUCT DESCRIPTION</b>	<b>MAXIMUM SIZE TESTED</b>
<b>Simonton Windows Code: SIM</b>		<b>8766</b>	<b>06-05 PICTURE (PVC) (O) (OG) (INS LAM GL) (ASTM)</b>	<b>FRAME 2724 mm x 1207 mm (8'11" x 4'0")</b>

2. This Certification will expire **March 13, 2021 (extended from March 13, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

**Architectural Testing, Inc.**

Report No: **B7917.01-501-47**

Date of Report: **April 3, 2012**

Missile Impact Test & Report by:

**Architectural Testing, Inc.**

Report No: **B7927.01-501-47 Rev. 2**

Date of Report: **April 17, 2012 (Revised June 11, 2012)**

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **May 7, 2012**

Revised: **November 24, 2015**

Cc: AAMA

SBS